

Ref.: AS2021-156

**RESULT OF ANALYSIS**

Organization / company	<b>HYDROLOGIC</b> Tel.: 098 666012
Type of sample	Influent and effluent water from ceramic filter
Sample submitted date	24 February, 2021

N	Code on Ceramic	Total coliform cfu / 100 mL	<i>E. coli</i> cfu / 100 mL
1	N. 1	0	0
2	N. 2	0	0
3	N. 3	0	0
4	N. 4	0	0
5	N. 5	0	0
6	N. 6	0	0
7	N. 7	0	0
8	N. 8	0	0
9	N. 9	0	0
10	N. 10	0	0
11	N. 11	0	0
12	N. 12	0	0
13	N. 1	0	0
14	N. 6	0	0
15	N. 12	0	0
16	Influent water	$1.1 \times 10^6$	$2.4 \times 10^5$
17	Standard for drinking water	0	0

Phnom Penh, 27 February, 2021  
Head of Laboratory